

LOS RIOS COMMUNITY COLLEGE DISTRICT

1919 Spanos Court, Sacramento, CA 95825
Phone (916) 568-3071 FAX (916) 568-3145
Purchasing Department



Sacramento City College American River College Cosumnes River College Folsom Lake College

ADDENDUM NO. 1

ISSUE DATE: October 20, 2017

SCC Lillard Hall Fume Hood Controls Prop 39

LRCCD BID NO. 18005

Issued By:

LOS RIOS COMMUNITY COLLEGE DISTRICT
1919 Spanos Court, Sacramento, CA 95825
Phone (916) 568-3071 Fax (916) 568-3145

This addendum forms a part to the Contract Documents. The addendum items supersede and supplement all portions of the bidding documents with which it conflicts. All workmanship, materials, appliances and equipment which may be included in the following addendum items shall be of the same relative quality as described for similar work set forth in the general or main specifications of which these addendum items shall be considered a part.

This Addendum has been acknowledged in the space provided on the Bid Form and is considered part of the bid documents.

This Addendum consists of 2 pages.

Question: M0.1 Fan Schedule Note 8 “provide motorized damper with end switch”

1. Is the damper actuator part of the fan assembly or does the actuator need to be provided by the BAS contractor?
2. This note is also shown for the Supply Fans – is that in error?

Response: Note 8 on the M1.0 Fan schedule shall be removed. No motorized dampers with end switches are necessary for this project.

Question: Project Manual Section 01 23 00 – ALTERNATES

1. Alternate No. 2 – Labs 110, 212, and 213 currently have existing digital thermostats (operational to the best of Honeywell’s knowledge). Could you please confirm that no additional T-stats, or replacement of the (E) T-stats are required for these three labs?

Response: No additional digital thermostat is needed for Labs 110, 212, and 213.

END OF SECTION.