

# LOS RIOS COMMUNITY COLLEGE DISTRICT

1919 Spanos Court, Sacramento, CA 95825  
Phone (916) 568-3071 FAX (916) 568-3145  
Purchasing Department

Sacramento City College American River College Cosumnes River College Folsom Lake College

---

## ADDENDUM NO. 2

ISSUE DATE: April 16, 2018

### Fiber Upgrade American River College LRCCD BID NO. 18029

Issued By:

LOS RIOS COMMUNITY COLLEGE DISTRICT  
1919 Spanos Court, Sacramento, CA 95825  
Phone (916) 568-3071 Fax (916) 568-3145

---

---

This addendum forms a part to the Contract Documents. The addendum items supersede and supplement all portions of the bidding documents with which it conflicts. All workmanship, materials, appliances and equipment which may be included in the following addendum items shall be of the same relative quality as described for similar work set forth in the general or main specifications of which these addendum items shall be considered a part.

This Addendum has been acknowledged in the space provided on the Bid Form and is considered part of the bid documents.

---

---

This Addendum consists of 2 pages.

RFI# 1: Will the school be providing and installing all SM patch cords during cut overs?

**RESPONSE #1: Yes**

RFI#2: In order to provide accurate and apple to apple proposals, can we get a general idea of OT/weekend/after hours work that might be required? Allowance of hours for everyone?

**RESPONSE #2: Please refer to Addendum 1, Division 10 21 00, Section 3.2 SCHEDULE OF ALLOWANCES, B.**

**3.2.1.1.1.1 SCHEDULE OF ALLOWANCES**

**American River College BID 18029**

**B. Contingency Allowance No. 2: Include a contingency allowance of 12% for use according to Owner's written instructions for scheduling additional, after hours and/or weekend work.**

RFI #3: The SCC campus MPOE looks like the distance from the entrance into the building to the termination point is more than 50ft, EIA/TIA standards for OSP riser rated cable is 50ft or less, indoor outdoor riser would be recommended, For proposal purposes and apple to apple pricing we recommend providing fiber part # preferred by the school district.( Pricing difference is substantial)

**RESPONSE #3: For the Installation of the new Single-Mode fiber, the distance of cable not in conduit is less than 50'.**

END OF SECTION.