

# LOS RIOS COMMUNITY COLLEGE DISTRICT

1919 Spanos Court, Sacramento, CA 95825  
Phone (916) 568-3071 FAX (916) 568-3145  
Purchasing Department

Sacramento City College American River College Cosumnes River College Folsom Lake College

---

## ADDENDUM NO. 2

ISSUE DATE: October 1, 2018

### FLC Electric Vehicle Charging Stations LRCCD BID NO. 18031R

Issued By:

LOS RIOS COMMUNITY COLLEGE DISTRICT  
1919 Spanos Court, Sacramento, CA 95825  
Phone (916) 568-3071 Fax (916) 568-3145

---

---

This addendum forms a part to the Contract Documents. The addendum items supersede and supplement all portions of the bidding documents with which it conflicts. All workmanship, materials, appliances and equipment which may be included in the following addendum items shall be of the same relative quality as described for similar work set forth in the general or main specifications of which these addendum items shall be considered a part.

This Addendum has been acknowledged in the space provided on the Bid Form and is considered part of the bid documents.

---

---

This Addendum consists of 2 pages.

RFIs & Responses:

RFI#1: Confirm drawing E1.2 note 7 – Data outlet & Ethernet cable are to be installed in conduit raceway from metering system to Tele room 002.

**RESPONSE #1: YES. Contractor will coordination with the District IT department for exact location of raceway and outlet prior to the installation.**

RFI#2: Please confirm landscape removal and put back is to be contractor responsibility.

**RESPONSE #2: YES**

RFI#3: Confirm plants / shrubs requirement for removal and put back. Required new plants due to existing plants dying upon removal, replacement plants shall be of same type in one-gallon container size.

**RESPONSE #3: YES**

RFI#4: Confirm if EVC anchor bolts are provided with owner provide chargers or provide size information if contractor provide.

**RESPONSE #4: Contractor to provide anchor bolts with nuts and washers per EV pedestal installation guide included in Project Specifications.**

RFI#5: Confirm Panel LAC & LACA breaker install & tie in to be performed on normal working hours.

**RESPONSE #5: Work may be performed during normal working hours, however, should any electrical shutdown be required, the contractor must follow the provisions contained in the Project Specifications, Summary of Work, Section 1.4(B)(3).**

RFI#6: Will badging and DOJ fingerprinting / back ground check be required? **RESPONSE #6: NO**

RFI#7: Will contractor be required to help with owner provided EVC' start up? **RESPONSE #7: YES**

END OF SECTION.